

APPENDIX-L

FORM "S"

[See RULE 87 (5)]

FIRE AUDIT REPORT

YEAR 2022-2023

To

**PALI ACADEMIC INSTITUTION
VILLAGE –BISONI, TEHI-LANJI, DIST-BALAGHAT (M.P.)**

Subject- submission of Fire Report of building: PALI ACADEMIC INSTITUTION

I, Vimal Lanjewar , B.E. Fire & Safety ,Authorized Fire engineer By Urban Administration & Development Department ,Bhopal(Madhya Pradesh)have inspected your building /permission on (dated) 06/11/2022,checked all fire- fighting equipment /installation and have completed the fire audit of said building premises.

The Said Premise is More Than 1000 sq meter of area and Shorter Than 12 meter height.

Details of fire system installed area below:

| Sr.no. | Particular | Available installed or not installed as per requirement | Comments for working of system (attached Details, if needed) |
|--------|--|---|--|
| 1 | Access | Available | Sufficient Space For Fire Brigade |
| 2 | Wet Riser | Not Required | |
| 3 | Down Comer | Required | |
| 4 | Hose reel | Required | |
| 5 | Automatic Sprinkler system | Not Required | |
| 6 | Yard hydrant | Not Required | |
| 7 | Underground water tank | Not available | |
| 8 | Terrace tanks | Available | 10000 Itr Capacity |
| 9 | Fire pump | Not Required | |
| 10 | Terrace pump | Required | |
| 11 | First Aid Fire fighting Appliances | 4/6 KG ABC TYPE-8 4.5 KG CO2 TYPE- 2 | AVAILABLE IN WORKING CONDITION |
| 12 | Pressurizes System | Not Required | |
| 13 | Auto Detection System | Not Required | |
| 14 | Manually Operated Electrical Fire alarm System | Not Required | |



| Sr.no. | Particular | Available installed or not installed as per requirement | Comments for working of system (attached Details, if needed) |
|--------|--|---|--|
| 15 | PA System with talk Back Facility | Required | |
| 16 | Emergency Light | Available | Working Condition |
| 17 | Auto D.G. Set | Inverter Available | Working condition |
| 18 | Illuminated Exit Sign | Required | |
| 19 | Means Of Escape | 2 Escape Route | Open Area |
| 20 | Compartmentation | Not Required | |
| 21 | MCB/ELCAB/RCCB/MCCB | Available | |
| 22 | Firemen Switch in Lift | Not Required | |
| 23 | Hose Boxes With Delivery Hose & Branch | Required | |
| 24 | Refuse area | Not Required | |
| 25 | Any Other Installation | Nil | |

It is Certified That Installed Fire Fighting Appliances Are in Working Condition and Safe.

Date -06/11/2022



 Signature
 Er. Vimal Lanjewar
 Approved by Urban Administration & Development
 Department, Bhopal